


LIGHTING CONTROL NOTES:

1. ALL COMMON AREA OUTDOOR LIGHTING MUST BE CONTROLLED BY A SCHEDULING DEVICE THAT ALLOWS THE LIGHTS TO BE DIMMED AT LEAST 50% PER CEC 130.2(C)2. LIGHT FIXTURES INSTALLED IN THESE AREAS SHALL BE DIMMABLE FIXTURES.
2. A MINIMUM OF 1 FT CANDLE AT THE WALKING SURFACE IS REQUIRED FOR MEANS OF EGRESS AND TO A SAFE DISPERSAL AREA PER CBC1008.2.1. OCCUPANCY SENSORS SHALL REDUCE LIGHTING LEVELS IF NO ONE IS PRESENT PER CEC130.2(C)3 OR EXCEPTION FOR FIXTURES LESS THAN 40WATTS, EXCEPTION 1, AND STAIRS, EXCEPTION 2 POINTS TO 140.7(A) EXCEPTION 6.
3. GENERAL PARKING LIGHTING HAS TO MEET THE SAME REQUIREMENTS, BE CONTROLLED BY A CLOCK THAT CAN SCHEDULE DIMMING, AND IF MORE THAN 40 WATTS PER FIXTURE AND IF LESS THAN 24' ABOVE GRADE, OCCUPANCY SENSORS, CEC130.2(C)3.
4. OCCUPANCY SENSORS (O.C.C.) MUST BE INSTALLED IN LIGHTING CIRCUITS CONTROLLING INDOOR COMMON AREAS WHICH ARE AUTOMATIC AND PROGRAMMED TO ADJUST LIGHTING LOADS IN ACCORDANCE WITH THE ACTIVITY OF A SPACE PER CEC 110.9.

LIGHTING PLAN

SCALE: 1/8"=1'-0"




LUMINAIRE SCHEDULE

CALLOUT	SYMBOL	LAMP	DESCRIPTION	BALLAST	MOUNTING	MODEL	INPUT WATTS	VOLTS	NOTE 1	NOTE 2	NOTE 3	QUANTITY
EX		(1)	EMERGENCY EXIT	ELECTRONIC	CEILING	CONTRACTOR SELECT / ECC R M6	1.4	120V 1P 2W	120 V, 1.4 W, 10 LM			4
GL		(1)	4' LINEAR FLUSH MOUNT	ELECTRONIC	CEILING	BOULDERCREST / FMLBDRLL LED	36	120V 1P 2W	120 V, 36 W, 3456 LM			28
HB		(1)	HIGH BAY LED	ELECTRONIC	CEILING	INDY / EXETER LED E3 G2	84	120V 1P 2W	120/277V, 84W, 10,134 LM			8
WP		(1)	WALL PACK EXT	ELECTRONIC	WALL	INDUSTRIAL LIGHTING PRODUCTS / WFS-3L-U-40-T3 BLK	22	120V 1P 2W	120V, 22W, 3203 LM	3000K		7

CFB 2301

90% SUBMITTAL

THESE PLANS ARE ORIGINALLY PRINTED ON 22"x34" PAPER.



This drawing or drawing set shall not be used for construction unless a jurisdictional stamp (County, City, State, Federal) has been issued on the drawing, stating "FOR PERMIT" or similar verbiage, a wet signed professional engineer's stamp, and permit documents have been issued for the project.

REVISIONS	BY

WHITCHURCH ENGINEERING, INC.
 610 9th Street Fortuna, California 95540
 Phone (707) 725-6926

**FORT BRAGG VOLUNTEER FIRE DEPARTMENT
 NEW FIRE STATION RECONSTRUCTION**
 APN: 008-161-13-00
 Site Address: 141 Main Street Fort Bragg, CA, 95437
 For: Fort Bragg Volunteer Fire Department 141 Main Street Fort Bragg, CA, 95437

LIGHTING PLAN

Date	JAN 18 '24
Scale	AS NOTED
Design	ETA
Drawn	GKK
Job	CFB2301
Sheet	L1