



# Water Distribution System Master Plan

City of Fort Bragg



December 8th, 2025

# Agenda

- **Introductions**
- **Treated Water Distribution System**
- **Purpose and Goals**
- **Master Planning Process**
- **Key Accomplishments**
- **Current Performance& Future Considerations**
- **Capital Plan**
- **Conclusion & Summary of Recommendations**

# Introduction

## Speakers



**Alex Johnson**  
Senior Project  
Manager



**Philip Tiewater**  
Principle-in-Charge

## City Team

**Chantell O'Neal**

Project Manager - Assistant Director - Engineering

**John Smith**

Director of Public Works

**Heath Daniels**

Operations & Maintenance Supervisor

**Diane O'Connor**

Assistant City Engineer

## HDR Team

**Scott Humphrey**

Technical Lead

**Allan Scott**

Technical Advisor

**Roger Null**

Technical Advisor

**Joel Griffin**

Mapping/GIS

**Mark Stanley**

Geotechnical Assessment

**Nathalie Beauvais**

Climate Impact Assessment

**Linda Fisher**

Environmental/Programmatic EIR

**Morgan DeAngelis**


Risk Analysis/Risk Model



# Treated Water Distribution System


This master plan assesses treated water distribution infrastructure starting at the treatment plant outlet and includes evaluation the following infrastructure:

- **41 miles of pipeline**
  - System Built (1960-2000s)
  - 6 to 20 inches in diameter
  - AC, PVC, DIP
- **4 Storage Tanks**
  - 1.5 to 1.6 MG
- **1 Pump Station and Pressure Zone (EFBPZ)**




# Purpose and Goals

## Purpose of the Master Plan



Considerations: **aging infrastructure**, **technological advances**, **community growth**, and **seismic**, **environmental**, and **climate risk**.

# Master Planning Process




# Key Accomplishments

1. **GIS database** to support hydraulic modeling, risk analysis, and current and future capital planning
2. System **hydraulic model**
3. Current and future **demand analysis**
4. Build-out **capacity analysis**
5. **Geotechnical & environmental risk analysis**
6. **Climate risk analysis**
7. **Risk assessment model**
8. **CIP plan**, including pipeline replacement strategy
9. Analysis of potential **funding opportunities**
10. **CEQA compliance strategy**
11. **Asset management strategy** and recommendations for implementation



# Today - Existing Water Distribution System

- Adequately satisfies current needs
- Performs well & in good condition
  - Well-maintained
  - Low break rates compared to other utilities
- Needs improvements to supply fire flows
- Reaching end of design life (next ~10 years)
  - Can expect problems to become more frequent
  - Plan now for system renewal






# Planning for the Future

## Treatment Capacity, Fire Flows, Expansion

- Sufficient water treatment capacity for current and likely future water demands
- Improvements to current fire flow capacity
  - Willow Creek Pump Station fire pump upgrade
  - Targeted pipeline improvements to address existing deficiencies
- Operational Improvements
  - Oak Street Isolation Valves
- Noyo Center water line




# Planning for the Future

## System Renewal

1% annual replacement rate recommended

### Targeted pipe replacement:

- Current information & Conditions
- Hydraulic Model
- Risk Model
- Opportunistic pipe sampling



# Planning for the Future: Risks

Seismic activity, drought, wildfire, sea-level rise

1. **Seismic Risk** – Bridge crossings vulnerable to movement; consider ERDIP or articulating joints for critical lines
2. **Densification** – Soil spreading or groundwater shifts may cause settlement damage
3. **Landslides & Bluff Erosion** – Differential settlement or pipe stretching from slope failures
4. **Soil Corrosivity** – Coastal soils more acidic, increased pipe corrosion risk
5. **Water Supply Resiliency Challenges**
  1. Increasing drought frequency and declining spring water availability
  2. Rising salinity and sea-level impacts at surface water intakes
  3. Continued evaluation of supply options is recommended




# Capital Plan – Next 5 Years

Priority	CIP ID	Project Name	Driver	Cost <sup>a</sup>
1	PS-1	Pump Station Upsize	Capacity or Fire Flow Deficiency	\$8,141,000
2	V-1	Oak Street Valves	Operational Improvements	\$93,000
3	P-1	Cedar Street Water Line Replacement	Capacity or Fire Flow Deficiency	\$3,357,000
4	T-1	Tank 1 Upgrade	Asset Renewal	\$8,955,000
5	P-2	North Fort Bragg Water Main Extension	Capacity or Fire Flow Deficiency	\$1,384,000
6	PL-1	System Renewal- Pipe Replacement	Asset Renewal <sup>b</sup>	\$2,830,000
7	O-1	Opportunistic Pipe Sampling	Other	\$69,000
8	O-2	CIP Update	Other	\$110,000
9	O-3	CMMS Needs Analysis	Other	\$39,000

Next 5 Year Sub-Total : **\$24,978,000**


<sup>a</sup> Project Costs Escalated for Inflation

<sup>b</sup> Budget reserved to meet system renewal goal. Projects to be identified based on condition and risk, or emergent issues





# Capital Plan – 5 to 10 Years



Priority	CIP ID	Project Name	Driver	Cost <sup>a</sup>
10	P-7	East Laurel Street Water Main Replacement	Capacity or Fire Flow Deficiency	\$354,000
11	P-3	Noyo Center Water Line <sup>b</sup>	Capacity or Fire Flow Deficiency	\$2,985,000
12	P-6	North Main Street Water Main Replacement	Capacity or Fire Flow Deficiency	\$4,016,000
13	P-14	East Alder Street Water Main Replacement	Capacity or Fire Flow Deficiency	\$470,000
14	P-10	Chief Celeri Dr Water Main Replacement	Capacity or Fire Flow Deficiency	\$951,000
15	P-4	Noyo Point Road Water Main Replacement	Capacity or Fire Flow Deficiency	\$455,000
16	P-8	Maple Street Water Main Loop	Capacity or Fire Flow Deficiency	\$206,000
17	P-5	East Elm Street Water Main Loop	Capacity or Fire Flow Deficiency	\$145,000
18	P-9	East Chestnut Street Water Main Replacement	Capacity or Fire Flow Deficiency	\$330,000
19	P-11	Spruce Street Water Main Replacement	Capacity or Fire Flow Deficiency	\$873,000
20	PL-2	System Renewal- Pipe Replacement	Asset Renewal <sup>c</sup>	\$3,280,000
21	O-4	Opportunistic Pipe Sampling	Other	\$80,000
22	O-5	CMMS Acquisition & Implementation <sup>c</sup>	Other	\$191,000
23	O-6	CIP Update	Other	\$127,000

<sup>a</sup> Project Costs Escalated for Inflation

<sup>b</sup>P-3 is dependent on development at the GP Mill site

<sup>c</sup> Budget reserved to meet system renewal

goal. Projects to be identified based on condition and risk, or emergent issues

**5-10 Year Sub-Total : \$14,463,000**



# Conclusion & Summary of Recommendations

- Purpose
  - Assess the current & future state
  - Identify near-term and long-term capital needs
- Infrastructure – good condition, well maintained, reaching the end of useful life.
  - Expect efforts to replace or renew aging infrastructure
- \$39M of capital projects over the next 10 years addressing aging infrastructure, fire flow, and City growth
  - Identified and prioritized to mitigate risk and to maintain current levels of service.



**Questions**





# Treated Water Capacity, Expansion, & Fire Flow

Average & Maximum Daily Water Demand Projections for Existing, Near-Term, and Buildout

Description	Residential	Non-residential	Water Loss (mgd) <sup>(2)</sup>	Total ADD (mgd)	Total MDD (mgd)
	ADD (mgd)	ADD (mgd)			
Existing Usage	0.428	0.156	0.11	0.58	1.01
Existing + Near Term Usage	0.440	0.165	0.11	0.61	1.05
Existing + Near Term + Buildout Usage	0.717	0.641	0.24	1.36	2.35



- Existing Demand: 1.01 MGD
- Near-Term Demand (next 10 years): 1.05 MGD
- Buildout Demand (> 10 years): 2.35 MGD
  - GP Mill Site, and Annexation areas

## Notes on Demand Analysis:

- Assessed water usage data from June 2018 to May 2021
- The city averages 0.59MGD with low density residential using the most (41%)
- Water loss for the City (23%) are above the national target (9-10%) but declining trend shows progress

# Risk Assessment

- Risk assessment done to prioritize capital improvement decisions in the Master Plan
- Risk model developed to assign relative risk score based on:
  - Likelihood of Failure (LoF)
  - Consequence of Failure (CoF)



Total Risk Score Map

# Funding

Table 26 – Potential Funding and Project Eligibility Matrix

CIP ID	Project Name	WIFIA	HUD CDBG	EDA Public Works	USDA Loans and Grants	EPA SRF
P-1	Cedar Street Line Replacement	X		X		X
V-1	Oak Street Valves	X		X		X
P-2	North Fort Bragg Water Main Extension	X		X		X
T-1	Tank 1 Replacement	X		X		X

Table 27 – Available Funding Summary

Source	Funding Type	Available \$	Notes
WIFIA	Long-Term Loan	49% of eligible projects over \$20M and \$5M for small communities	<ul style="list-style-type: none"> <li>• Interest rate based on U.S. Treasury Securities</li> <li>• Maturity up to 35 years</li> <li>• Sculpted debt</li> <li>• Letters of Interest on a rolling basis</li> </ul>
DWSRF	Loan/Some Grant Funding Available	\$391M	<ul style="list-style-type: none"> <li>• Low interest for 20-year maturity</li> <li>• Available \$ = CA FY25 funding allocation</li> <li>• Amount of funding likely to decline after 2026</li> <li>• Broad eligibility</li> </ul>
HUD Community Development Block Grants	Grant	2025 Allocation not announced	<ul style="list-style-type: none"> <li>• Funds allocated to state, city, and county</li> <li>• Project must resolve a problem that will help revitalize the community</li> <li>• Short project completion window, 24 months</li> </ul>
EDA Public Works and Economic Adjustment	Grant	\$30 million	<ul style="list-style-type: none"> <li>• Must promote economic development in disadvantaged areas</li> <li>• Percent match requirements depending on disadvantaged status</li> </ul>
USDA Water and Wastewater Loans and Grants	Predominately loans and some grants	Varies based on annual funding allocations	<ul style="list-style-type: none"> <li>• Projects must serve rural communities (population less than 10,000)</li> <li>• Interest rates vary based on communities' disadvantaged status</li> <li>• Up to 40-year payback period</li> </ul>

# Raw Water Supply Planning

- The City of Fort Bragg does not currently meet the supplier criteria that would require development of an Urban Water Management Plan (UWMP)
  - Does not serve more than 3,000 customers
  - Or supply more than 3,000 acre-ft of treated water annually
- In the absence of a formal UWMP the City has taken measures to assess and address the adequacy and reliability of their raw water supply.
  - 2015 - Water-Supply Model – To evaluate water-supply scenarios
  - 2016 – Construction of the 45 acre-ft Summers Lane Reservoir
  - 2023 – Pipeline improvements, including pressurized pipe and pump station force main at Newman Gulch.
  - 2025 – Preliminary Engineering Reports Established for three new 45-acre-foot reservoirs, building off existing water rights



# Environmental Compliance

CIP ID's	Expected LOE for CEQA Compliance
V-1	Exemption: Class 1
T-1	Exemption: Class 2
P-1, P-3, P-4, P-5, P-6, P-7, P-8, P-9, P-10, P-11, P-12, P-13, PS-1, P-2, P-14	Initial Study / Mitigated Negative Declaration
P-15, P-16	Environmental Impact Report

- **Class 1 Exemption:** Existing facilities
- **Class 2 Exemption:** Replacement or reconstruction.
- **Initial studies (IS):**
  - May result in either a negative declaration or mitigated negative declaration
- **Environmental impact reports (EIR):**
  - Required when significant impacts are found that cannot be mitigated to less than significant levels. Involve more evidence, process, time, and include a period of public review.

# Capacity and Expansion

Table 10 – ADD and MDD Water Demand Projections for Existing, Near-Term, and Buildout

Description	Residential	Non-residential	Water Loss (mgd) <sup>(2)</sup>	Total ADD (mgd)	Total MDD (mgd) <sup>(3)</sup>
	ADD (mgd)	ADD (mgd)			
Existing Usage <sup>(1)</sup>	0.428	0.160	0.106	0.694	1.20
Existing + Near Term Usage	0.440	0.170	0.110	0.720	1.24
Existing + Near Term + Buildout Usage	0.710	0.644	0.244	1.60	2.76

<sup>(1)</sup> GP Mill site area not included in the existing and near-term projections since it will only have water demand during buildout.

<sup>(2)</sup> Water loss calculated assuming that water loss remains the same as 2021 average (i.e., 18%).

<sup>(3)</sup> MDD water demand projection calculated based on the selected MDD:ADD peaking factor of 1.73.

- **Existing Demand: 0.70 MGD**
- **Near-Term Demand** (next 10 years): **0.72 MGD**
  - Recent developments including housing, retail, and hotels. Annexation areas.
- **Buildout Demand** (> 10 years): **1.6 MGD**
  - GP Mill Site, and Annexation areas

## Notes on Demand Analysis:

- Assessed water usage data from June 2018 to May 2021
- The city averages 0.59MGD with low density residential using the most (41%)
- Water loss for the City (23%) are above the national target (9-10%) but declining trend shows progress

# Geotechnical Evaluation & Risk

- City is located on a seismically active, uplifted coastal terrace
- **Seismic risk**
  - Not within a fault line.
  - Differential movement especially at bridge crossings may pose risk to distribution
    - **Mitigation strategies may include:**
      - Use of articulating joints
      - Earthquake Resistant Ductile Iron Pipes (ERDIP) for critical infrastructure
- **Densification/Liquification**
  - Significant settlement due to soil spreading or groundwater fluctuation could damage system
- **Land Slides & Bluff Erosion**
  - Differential settlement or pipe lengthening due to landslides pose risk to the system
- **Corrosivity**
  - Terrace deposits are acidic (corrosive) and become more so gradually closer to the ocean.

# Environmental Evaluation & Risk

- **Flooding** - The City is susceptible to flooding and severe winter storms.
- **Fire** - significant fires have occurred in Northern California in the last few years and the City's fire hydrant system is critical infrastructure for public safety
- **Chemically impacted sites** - Many of these sites are identified as having been remediated to meet standards set forward by regulatory agencies.
  - It should be noted that there may be residual chemically impacted soils that may require special testing and handling to determine material reuse or disposal.
  - The DTSC GeoTracker website should be referenced during future system upgrade or rehabilitation projects.



# Environmental Evaluations

## Climate Change Impacts

- **Hotter temperatures**
  - Adds demand and stress to the water system and exacerbates wildfire threat to infrastructure
- **Variability in precipitation**
  - May cause floods or droughts
- **Sea level rise**
  - Increase risks of landslides and erosion
  - Increase in salt-water intrusion to freshwater supply areas

## Climate Change Mitigation

- Require varied and more adaptable water management
- Water distribution assets which may benefit the most from implementing resilience strategies include:
  - Pump station
  - Mains
  - Storage tanks
  - Water treatment plant

# Environmental Practices

- **Water efficiency:**

- Raw Water Line Replacement Project (Dewberry 2022) is upgrading critical infrastructure to improve reliability and efficiency of 2 mile section of aging raw water deliver pipeline
- Oneka Seawater Desalination Buoy Pilot Study designed to enhance resilience and efficiency of the water supply system of Fort Bragg
- Increasing reservoir storage to improve long-term water supply reliability and enhance drought resilience
- Regulating new and retrofitted landscapes for better water efficiency through new standards

- **Conservation:**

- Identified priority species
- Removal of fish passage barrier in 2016 from Newman Gulch
- City plans to continue considering ways to protect these populations

# T-1 Tank 1 Replacement

**CIP Year:** ??

**Description:** Replace existing Tank 1 at the Water Treatment Plant.

**Project Driver:** Aging Infrastructure – repairs necessary

**Expected Env. Compliance:** Exemption: Class 2 for Replacement or Reconstruction

**Projected Project Cost:** \$8,955,000

**Funding Opportunities:** WIFIA, EDA Public Works, EPA SRF

